

**OSCEOLA COUNTY DISTRICT SCHOOLS**  
ANNUAL COMPREHENSIVE SAFETY INSPECTION

F.I.S.H. 0853

SchoolName New Dimensions High School

For School Year 7/01/2009 to 6/30/2010

Address 1900 Old Pleasant Hill Road

Date of Inspection: 3/31/2010

City Kissimmee

State Florida

Fire Code	RuleID	Priority	Bldg	Room	Ext	Est. Cost	Type	Deficiency	Times Cited	Cor. Period
-	1(e)8i	B	01	006		\$100.00	M	Ceiling shows water damage-repair leak & replace damaged material	0	60
-	1(e)8i	B	01	100		\$0.00	O	Clean cobwebs from walls and/or ceiling	0	60
-	1(e)8g	E	01	101		\$40.00	M	Light shield is damaged and needs to be repaired/replaced	1	30
804	17(b)	B	01	102		\$0.00	O	Extension cords are not approved for long term use - remove	0	60
211	101-7.1.10.2	C	01	102		\$0.00	O	Exit is obstructed - keep clear	0	30
106	101-15.7.4.3(1)	F	01	103		\$0.00	O	Combustibles cover more than 20% of walls-reduce amount	1	30
211	101-7.1.10.2	C	01	104		\$0.00	O	Exit is obstructed - keep clear	0	30
106	101-7.1.10.2.1	F	02	100		\$0.00	O	Combustibles are excessive in corridor	0	30
-	1(e)8i	B	02	206		\$100.00	M	Ceiling shows water damage-repair leak & replace damaged material	0	60
-	1(e)3	B	03	306		\$0.00	O	Chemical bottles must be labeled with content	0	60
-	N/A	N	04	0000		\$0.00	N	No deficiencies noted	0	0
-	N/A	N	05	0000		\$0.00	N	No deficiencies noted	0	0
804	17(b)	B	06	101		\$0.00	O	Extension cords are not approved for long term use - remove	0	60
-	N/A	N	07	0000		\$0.00	N	No deficiencies noted	0	0

Inspector Signature: *J. Beckman* Date of Inspection: *3/31/10* Telephone Number: *407-870-1088*

Inspector Signature: *N/A* Reinspection Date: *N/A*

Print Name: *J. Beckman* Address: 817 Bill Beck Blvd., Kissimmee, Florida 34744

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY: Emergency Evacuation Drills Held Once Every Month **Yes / No**

Approval of Reports by Board (including letter) **Yes / No** The District has compiled with Section 1013.12(1)(c) F.S. **Yes / No**

OSCEOLA COUNTY DISTRICT SCHOOLS

ANNUAL COMPREHENSIVE SAFETY INSPECTION

For School Year 7/01/2009 to 6/30/2010

Date of Inspection: 3/31/2010

F.I.S.H. 0853

SchoolName New Dimensions High School

Address 1900 Old Pleasant Hill Road

City Kissimmee

State Florida

The Local Fire Authority has complied with Section 1013.12(2)(c) F.S. **Yes / No**

Signature of Facility Administrator attesting to Emergency Evacuation Drills and Review of Report Acknowledging awareness of discovered deficiencies:

Administrator Signature:     *Jaqueline Quinn*     Date:     4-13-10